

2017 Annual Drinking Water Quality Report (Consumer Confidence Report)

FALLBROOK UTILITY DISTRICT
PWS ID No. TX1010340 **Phone No: 281-895-8547**

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which come from sewage treatment plants, septic systems, agricultural livestock operations, and
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office. You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infections by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791

En Español

Public Participation Opportunities

Date: 3rd Monday of Each Month

Time: 2:00 PM

Location: 13563 Bammel N. Houston
Houston, Texas 77066

Phone No: 281-895-8547

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español, favor de llamar al tel. (281)895-8547 para hablar con una persona bilingüe en español.

Information about Source Water Assessments

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact [281-895-8547].

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:
<http://www.tceq.texas.gov/gis/swaview>.

Further details about sources and source water assessments are available in Drinking Water Watch at the following URL:
<http://dww.tceq.texas.gov/DWW/>.

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondary constituents are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

About The Following Pages

The pages that follow list all federally regulated or monitored contaminants, which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Maximum Contaminant Level Goal or MCLG:	The level on contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Contaminant Level or MCL:	The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Action Level Goal (ALG):	The level of contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.
Level 1 Assessment:	An evaluation to identify the possible presence of Sanitary Defects, defects in distribution system coliform monitoring practices, and (when possible) the likely reason that the PWS triggered the assessment. As defined in Title 30 Texas Administrative Code (TAC) §290.103(35), a Sanitary Defect is: "A defect that could provide a pathway of entry for microbial contamination into the distribution system or that is indicative of a failure or imminent failure in a barrier that is already in place.
Level 2 Assessment:	An evaluation to identify the possible presence of sanitary defects, defects in distribution system coliform monitoring practices, and (when possible) the likely reason that the public water system triggered the assessment. . .Minimum elements include review and identification of atypical events that could affect distributed water quality or indicate that distributed water quality was impaired; changes in distribution system maintenance and operation that could affect distributed water quality (including, but not limited to, water storage); source and treatment considerations that bear on distributed water quality, where appropriate; existing water quality monitoring data; and inadequacies in sample sites, sampling protocol, and sample processing."
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
ppm:	Milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
ppb:	Micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
na:	Not applicable.
TCR:	Total coliform rule
MFL	Million fibers per liter (a measure of asbestos)
NTU	Nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppt:	parts per trillion, or nanograms per liter (ng/L)

ppq:

parts per quadrillion, or pictograms per liter (pg/L)

mrem/yr

millirem per year

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	7/2/15	1.3	1.3	0.051	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	7/2/15	0	15	3.2	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants Detected

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	12/5/2016	0.332	0.332 – 0.332	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2017	90	0 - 90	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel / metal factories.
Fluoride	2017	0.16	0.16 – 0.16	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum.
Nitrate [measured as Nitrogen]	2017	0.25	0.13 – 0.25	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2017	4.3	4.3-4.3	0	4	mrem/yr	N	Decay of natural and man-made deposits.

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Gross alpha excluding radon and uranium	2017	7.1	4 – 7.1	0	15	pCi/L	N	Erosion of natural deposits.
Uranium	2017	4.1	4.1 -4.1	0	30	ug/l	N	Erosion of natural deposits.

Volatile Organic Compounds	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Xylenes	2017	0.0005	0-0.0005	10	10	ppm	N	Discharge from petroleum factories; discharge from chemical factories.

Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine	2017	1.78	1.0-2.2	4	4	ppm	N	Water additive used to control microbes.