

2024 Annual Drinking Water Quality Report

(Consumer Confidence Report)

HARRIS COUNTY MUNICIPAL UTILITY DISTRICT NO. 109

PWS ID No. TX1010620

Phone No: 281-895-8547

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infections by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water Assessments

The water source for Harris County Municipal Utility District 109 is groundwater from the Gulf Coast Aquifer.

The TCEQ completed an assessment of your source water and results indicated that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact WWWS, Inc. at 281-895-8547.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:
<http://www.tceq.texas.gov/gis/swaview>.

Further details about sources and source water assessments are available in Drinking Water Watch at the following URL:
<http://dww2.tceq.texas.gov/DWW/>.

Public Participation Opportunities

En Español

Date: 3rd Tuesday of Each Month

Time: 5:30 PM

Location: Atascocita Waste Water Treatment Plant
5003 Atascocita Road
Humble, Texas 77346

Phone No: 281-895-8547

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono. (281)895-8547

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

About The Following Pages

The pages that follow list all federally regulated or monitored contaminants, which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

Water Quality Test Results

Definitions and Abbreviations:

Action Level:

The following tables contain scientific terms and measures, some of which may require explanation. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level Goal:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL:

The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum residual disinfectant level goal: MRDLG

The level of a drinking water disinfectant below which there is no known or expected MRDLG risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

ppm:

Milligrams per liter or parts per million.

ppb:

Micrograms per liter or parts per billion.

na:

Not applicable.

TCR:

Total coliform rule.

MFL:

Million fibers per liter (a measure of asbestos).

mrem:

Millirems per year (a measure of radiation absorbed by the body).

NTU:

Nephelometric turbidity units (a measure of turbidity).

pCi/L:

Picocuries per liter (a measure of radioactivity).

ppt:

Parts per trillion, or nanograms per liter (ng/L).

ppq:

Parts per quadrillion, or picograms per liter (pg/L).

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants Detected**Lead and Copper**

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2022	1.3	1.3	0.138	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems

HCMUD 109 has developed an inventory of both city-owned and customer-owned service lines. This inventory serves as a crucial foundation for water systems to address a significant source of lead in drinking water. To access the inventory, please visit/contact 281-895-8547.

Regulated Contaminants

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2/18/20	3	3 - 3	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2023	0.282	0.27 – 0.27	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2023	0.13	0.12 – 0.13	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Di (2-ethylhexyl) phthalate	2020	1	0 – 0.74	0	6	ppb	No	Discharge from rubber and chemical factories

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Gross alpha excluding radon and uranium	2/10/22	3	0-3	0	15	pCi/L	N	Erosion of natural deposits.

Disinfectant Residual

Disinfectant	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Likely Source of Contamination
Free Chlorine	2024	1.83	1.1 - 2.2	4	4	ppm	N	Water additive used to control microbes.

UCMR5

Unregulated Contaminant	Collection Date	Average Level (µg/L)	Range of Levels Detected (µg/L)
Lithium	2023	11.05	10.6-11.3