

2025 Annual Drinking Water Quality Report

(Consumer Confidence Report)

HARRIS COUNTY MUNICIPAL UTILITY DISTRICT NO. 150
PWS ID No. TX1011250 Phone No: 281-895-8547

Public Participation Opportunities	En Español
Date: 3rd Tuesday of Each Month Time: 6:00 PM Location: 13563 Bammel N. Houston Rd. Houston, Texas 77067 Phone No: 281-895-8547 To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call 281-895-8547.	Este reporte incluye información importante sobre el agua para tomar. Para asistencia en informe en español, favor de llamar al tel. (281)895-8547.

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water (Este informe contiene informacion muy importante sobre so agua potable. Tradúzcalo o hable con alguien que lo entienda bien).

Sources of Drinking Water

The source of water for HARRIS COUNTY MUNICIPAL UTILITY DISTRICT 150 is Purchased surface water from CHCRWA in Harris County, TX, which purchases it from the City of Houston which gets water from Lake Conroe, Lake Houston and Lake Livingston.

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
1 - 11919 LOVELAND PASS / PLUGGED	11919 LOVELAND PASS	Ground water	NO	Houston, TX
2 - 12010 ANTOINE DR / PLUGGED	12010 ANTOINE DR.	Ground water	NO	Houston, TX
3 - 11919 LOVELAND			NO	Houston, TX
4 - 12010 ANTOINE DR		Ground water	NO	Houston, TX
SW FROM HOUSTON THRU CHCRWA		Surface water	NO	Houston, TX

The TCEQ completed an assessment of your source water and results indicated that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact WWWMS, Inc. at 281-895-8547.

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

A lead service line inventory was conducted, and no lead, galvanized requiring replacement, or unknown service lines were documented. The location of service lines with unknown material types can be found on the published Lead Service Line Inventory.

A service line inventory has been prepared and can be accessed at 281-895-8547.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. HARRIS COUNTY MUNICIPAL UTILITY DISTRICT 150 is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact HARRIS COUNTY MUNICIPAL UTILITY DISTRICT 150 at 713-623-4531. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In the Water Loss Audit submitted to the Texas Water Development Board for the time period of January 2025 – December 2025, our system lost an estimated 7,143,654 gallons of water. Overall, our system accounted for approximately 97.06% of the water produced during that period. If you have any questions about the water loss audit, please call 281.895.8547.

About The Following Pages

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Water Quality Test Results

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

Picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant Residual	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Chloramines	2025	2.57	mg/l	0-2.57	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90 th Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low-high)	Unit	AL	Sites Over AL	Typical Source
Copper, Free	2023-2025	0.0341	0.00108-0.0994	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
Lead	2023-2025	0	0-0.771	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
Total Haloacetic Acids (HAA5)	11918 Loveland Pass Dr., Houston	2025	13	7.8	ppb	60	0	Byproduct of drinking water disinfection.
Total Haloacetic Acids (HAA5)	12130 E Marsham Cir., Houston	2025	12	7.5	ppb	60	0	Byproduct of drinking water disinfection.
Total Trihalomethanes (TTHM)	11918 Loveland Pass Dr., Houston	2025	18	16.9	ppb	80	0	Byproduct of drinking water disinfection.
Total Trihalomethanes (TTHM)	12130 E Marsham Cir., Houston	2025	12	7.5	ppb	80	0	Byproduct of drinking water disinfection.

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Atrazine	1/28/25	0.15	0.14-0.15	ppb	3	3	Runoff from herbicide used on row crops.

Barium	1/28/25	0.452	0.452	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	7/24/2023	70	30-70	ppb	0	200	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories..
Dibromochloromethane	4/8/25	3.4	1.5-3.4	UG/L	0	0.06	
Nickel	1/28/25	0.0013	0.0013	MG/L	0	0.1	
Nitrate	1/28/25	1/23	1.16-1.23	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks; sewage; Erosion of natural deposits.
Simazine	1/28/25	0.07	0-0.07	ppb	4	4	Herbicide runoff.
Fluoride	2023	70	30.– 70	200	200	ppm	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2024	0.48	0.48 – 0.48	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks; sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Gross Beta Particle Activity	3/23/22	6.9	6.8-6.9	pCi/L	50	0	Decay of natural and man-made deposits.
Beta/photon emitters	3/23/22	6.9	6.8-6.9	pCi/L	50	0	Decay of natural and man-made deposits.

***** In 2025, Harris County Municipal Utility District No 150 purchased water from Central Harris County Regional Water Authority. The following tables contain all of the chemical constituents which have been found in their water. For water quality information, please call (281) 367-5511.**

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2024	14	13.7 – 13.7	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year.

Total Trihalomethanes (TTHM)	2023	24	24.3 – 24.3	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate (measured as Nitrogen)	2024	1	0.81 – 0.81	10	10	ppm	N	Runoff from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits.

UCMR 5

The Fifth Unregulated Contaminant Monitoring Rule (UCMR 5) was published on December 27, 2021. UCMR 5 requires sample collection for 30 chemical contaminants between 2023 and 2025. The data collected under UCMR 5 improves understanding of the prevalence and amount of 29 per- and polyfluoroalkyl substances (PFAS) and lithium in the nation's drinking water systems.

Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. Any unregulated contaminants detected are reported in the following table. For additional information and data visit <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule> or call the Safe Drinking Water Hotline at (800) 426-4791.

Unregulated Contaminant	Collection Date	Average Level (µg/L)	Range of Levels Detected (µg/L)
PFTA	2023	.0018	0-.0071
PFBA	2024	0.0052	.0051-.0052
PFHxA	2024	0.0021	.0003-.0055
PFPeA	2024	0.0062	.0054-.0069
PFTTrDA	2023	.0012	0-.0046
NEtFOSAA	2024	.0011	0-.0042
NMeFOSAA	2023	.0017	0-.0067